

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213952
Address: 3100 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, May 06, 2022

Corrective Action Required:

1	Misc
	-fire block furr out at rear garage wall
	-anchor bolts in basement to be tight and within 12" of plate breaks
	5/6/22
	- Support gas line to deck fire place
	- Fire block south basement wall at top plate

Comments: