

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20212952
Address: 3034 NW THOREAU PL, LEES SUMMIT, MO 64081
Inspected On: Monday, May 09, 2022
Inspected By: Robb Popp
Expiration Date: 5/30/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Temporary C of O	Monday, May 09, 2022

Corrective Action Required:

- | | | |
|---|-----------------------------|---|
| 1 | Miscellaneous
Correction | TCO UNTIL 5/30/22

- Final grading and sod
- Possible guard needed at north end of porch depending upon
grading
- Sump discharge minimum of 36" away from foundation
- Seal top of A/C disconnect
- Seal top of lights at garage |
|---|-----------------------------|---|