

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20213400
Address: 2942 SW ARBORIDGE DR, LEES SUMMIT, MO 64082
Inspected On: Monday, May 09, 2022
Inspected By: Mitchell Schwarz
Expiration Date: 6/9/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Temporary C of O	Monday, May 09, 2022

Corrective Action Required:

1	Misc	TCO UNTIL 6/9/22
---	------	------------------

- sod
- seal top of meter can, A/C disconnect and all other exterior penetrations
- check water meter and pit at time of final grade and sod
- submit as graded plot plan