



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20100288, Building Permit - Commercial
Address: 622 SW 3RD ST, Unit:D, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Plumbing Inspection - Commercial	John Borns	Passed	Tuesday, December 28, 2010
Final Plumbing Inspection - Commercial	John Borns	Passed	Tuesday, December 28, 2010

Comments: PRIOR TO RE-INSTALLATION OF GWB RECOMMEND APPLICATION OF SHIELD PLATES TO PROTECT EXISTING PVC PIPING. AFTER RE-INSTALLATION OF GWB RECOMMEND FURTHER SECURING OF PEX TUBING. CLOSE PERMIT.