

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20216366

Address: 3635 NE AKIN DR, Unit:WTR, LEES SUMMIT, MO 640643691 NE AKIN DR, Unit:WTR, LEES SUMMIT,
MO 640643695 NE AKIN DR, Unit:WTR, LEES SUMMIT, MO 640643635 NE AKIN DR,
Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 1	Eric Sharp	Partial	Monday, May 09, 2022

Informational:

1 Misc 5-2-22 AN. On 4-29-22 josh with Holthouse chlorinated the fire line and dechlorinated on 5-2-22 and we will be taking the first sample on 5-3-22

Informational:

2 Misc 5-3-22 AN. First sample was taken on the fire line at 10:00 am

Informational:

3 Misc Sample #1 taken at 11:15 and delivered to keystone labs. 5/9/22 ES

Comments: