

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20215945

Address: 2101 SE HAMBLER RD, LEES SUMMIT, MO 640822620 SE RANSON RD, LEES SUMMIT, MO
640821971 SE HAMBLER RD, LEES SUMMIT, MO 640821240 SE HOOK LN, LEES SUMMIT,
MO 640821745 SE HAMBLER RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------------|------------|----------|----------------------|
| Sanitary Sewer - Air Test | Tom Taylor | Passed | Monday, May 09, 2022 |

Informational:

1 Misc

On Monday 5-09-2022. Daniel for Redford Excavating air tested the first 7 sections of Ductile iron pipe before we came to the first water crossing. The test passed holding the 4lbs of pressure for 28min. Contractor will resume installation of pipe.

Comments: