

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20100041	Date:	December 28, 2010
Project Title:	Progressive Insurance	Applicant:	
Project Address:	400 SW LONGVIEW BLVD, Unit:125 LEES SUMMIT, MO 64081	Consolidated Fire Protection	
Location:		14130 Dugan Drive	
Type of Work:	Sprinkler Alteration	Kansas City, MO 64152	
Occupancy Group:	B		
Description:	TENANT SPACE FOR PROGRESSIVE		
INSURANCE			
Construction Type:	Type IIB (Unprotected)		
Map Page:	194E		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Released for Construction

1. Fire Department-2006 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

Action required: The existing system shall have documentation of a current annual inspection.

2. Fire Department -2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Action required: Call (816) 969-1300 to schedule alarm and sprinkler inspection.

3. Fire Department- Sprinkler plans shall be designed to the 2002 edition of NFPA 13.

Note only: There isn't a 2003 edition.