

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20210022
Address: 333 NW AMBERSHAM DR, LEES SUMMIT, MO 64081
Inspected On: Tuesday, May 10, 2022
Inspected By: Michael Harkins
Expiration Date: 5/27/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Temporary C of O	Tuesday, May 10, 2022

Corrective Action Required:

1	Misc	TCO UNTIL 5/27/22
---	------	-------------------

-check siding from ground at time of sod
PROVIDE 6 INCHES CLEARANCE FROM WOOD SIDING TO GRADE
(1018 IRC R317.1 (5)

Obtain Lawn irritation permit & submit back flow certification

LAND SEWER TRACER WIIRE IN A BOX AT GRADE LEVEL