

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20215781  
Address: 4732 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Tuesday, May 10, 2022

Corrective Action Required:

1	Misc	-Fireblock top of dwv chase
		-Address over bored stud in load bearing wall at laundry **nail the trim to stud to reinforce it; Fireblock top of fur out in laundry
		-Strap top plates bored more than 50% at laundry bearing wall
		-Land electrical at top of stairs
		-Provide structural straps at top plates bored greater than 50% in LBW at hallway and bed 2/3
		**MAKE SURE TO INSULATE THE 2ND FL LAUNDRY PLUMBING
		**OK TO INSULATE

Comments: