

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215493  
Address: 2023 SW WHEATFIELD CT, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Not Ready	Tuesday, May 10, 2022

Corrective Action Required:

1	Misc	-PFH nailing to plans/code -cs-pf at rear slider remove trim to view nailing pattern -protect NM within 6' of attic access bed 3 closet -vertical to horizontal fireblock if every 10' in basement seal gaps and penetrations -seal top of furr out walls in basement seal gaps -fire block furr down ends in basement
---	------	---

**Comments:**