

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212062
Address: 2105 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Eric Sharp	Failed	Tuesday, May 10, 2022

Informational:	
1 Misc	Forms were placed and aggregate was present and compacted. Had them adjust the forms around the curb inlet because they were out of tolerance. RP 4-13-22

Corrective Action Required:	
2 Misc	Sidewalk covered with silt. Need to clean off before final inspection for compliance. RP 4-22-22

Corrective Action Required:	
3 Misc	Sidewalk has a busted panel that needs replaced. The rest of the sidewalk meets LS and ADA specs. 5/10/22 ES

Comments: