

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220128
Address: 102 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Michael Harkins	Failed	Tuesday, May 10, 2022

Corrective Action Required:

1	Miscellaneous Correction	INSPECTION DENIED NO SILT FENCE ON SOUTH SIDE OF LOT CALLED CRAIG ABOUT INSTALLING SILT FENCE ON SOUTH & MAINTAINING SILT FENCE ON AMBERSHAM
---	-----------------------------	--

Comments: