CITY OF LEE'S SUMMIT

CODES ADMINISTRATION DEPARTMENT

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 Fax (816) 969-1201

PLANS REVIEW CONDITIONS

Permit No: PRCOM20100231 Date: December 29, 2010

Project Title: Glo Nail Lounge Applicant:

Project Address: 930 NW BLUE PKWY, Unit:P,

LEES SUMMIT, MO 64086 SCHARHAG ARCHITECTS
Location: SUMMIT FAIR LOTS 22A & 310 ARMOUR RD #218A

24A---LOT 22A NORTH KANSAS CITY, MO 64116

Type of Work: New Tenant Finish

Occupancy Group: Business
Description: Tenant finish

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200 Fire Department (816) 969-1300

Building Plan Review Reviewed By: Tracy Deister Approved

Fire Plan Review Reviewed By: Brian Austerman Approved

1. Fire Department- 2006 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Action required: Provide a minimum of one 2A:10B:C fire extinguisher at a conspicuous location. Verified at inspection.,

2. Fire Department- 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Action required: Provide shop drawings for sprinkler alteration.,

3. Fire Department- 2006 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Action required: Provide shop drawings for alarm system alteration.,

4. Fire Department- 2006 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

Verified at inspection.,

For information only.,

5. Fire Department- 2006 IFC 901.5.1- Occupancy. It shall be unlawful to occupy any portion of a building or structure until the required fire detection, alarm and suppression systems have been tested and approved.

Approved to issue per the listed conditions.			
Do not issue per the listed conditions. Approved to construct foundation only per the listed conditions. Requires Final Development Plan approval prior to issuing this building permit.			
		Codes and Ordinances.	d requirements into the project to conform to applicable City
Signature of Applicant	Date		

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.