

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212481
Address: 3224 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, May 11, 2022

Corrective Action Required:

1	Misc	-complete final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation -seal top of meter can,A/c disconnect and all other exterior penetrations. -security screws at back door hinges and strike plates per city security code
---	------	--

Comments: