

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20204934  
Address: 1440 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Michael Harkins	Failed	Wednesday, May 11, 2022

Corrective Action Required:

1	Miscellaneous Correction	COMPLETE H2.5s NORTH END ROOF NAIL EXTERIOR WALL SHEETING MARKED ON SOUTH END  ROOF SHEATHING NAILING APPROVED OK TO COVER  PROVIDE CITY APPROVED TRUSS PLANS & LAYOUT
---	-----------------------------	---

**Comments:**