

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212466
Address: 508 SE DAVID RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--------------------------------------|------------|----------|-------------------------|
| Electrical Service Inspection | Robb Popp | Failed | Wednesday, May 11, 2022 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | NO PRESSURE ON GAUGE, IDENTIFY BONDING CONDUCTOR WITH GREEN AT BOTH ENDS |
|---|------|--|

Comments: