CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20214080Address:2005 SW OSAGE DR, LEES SUMMIT, MO 640822003 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Patrick Schonfeldt	Failed	Wednesday, May 11, 2022

Corrective Action Required:

1 Misc

Roof 4' plywood at front ridge. Address damaged fire rock Roof fire rated plywood at connection missing. Missing "C" channel at top of shaft walls

Comments: