

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20214081

Address: 2009 SW OSAGE DR, LEES SUMMIT, MO 640822011 SW OSAGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Patrick Schonfeldt	Failed	Wednesday, May 11, 2022

Corrective Action Required:

1 Misc

Missing "C channel at fire rock roof deck  
Address damaged fire rock  
Fire rock not seated in H track  
No vents allowed in first 4' of firewall at fire rated plywood  
Fire rated partition required at basement foundation rear corner per plan

**Comments:**