

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215494  
Address: 2130 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:            | Inspector:       | Outcome: | Date:                      |
|------------------------|------------------|----------|----------------------------|
| <b>Erosion Control</b> | Mitchell Schwarz | Failed   | Wednesday, May 11,<br>2022 |

Corrective Action Required:

|   |   |  |
|---|---|--|
| 2 | DCM1 ESC<br>REQUIRED NO<br>FURTHER INSP | EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE<br>PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE.<br>-maintain gravel filter<br>-maintain silt fence |
|---|---|--|

**Comments:**