

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213997  
Address: 605 NW REDBUD DR, Unit:B, LEES SUMMIT, MO 64081  
605 NW REDBUD DR, Unit:A, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Michael Harkins	Failed	Wednesday, May 11, 2022

Corrective Action Required:

1	Miscellaneous Correction	Derate feeder cables in attic for ambient temperatures ( 2017 NEC 310.15 ) Provide meter can/ disconnect Land SEC cables in meter can
---	--------------------------	---

**Comments:**