

# LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS  
207 SE DOUGLAS STREET  
LEE'S SUMMIT, MISSOURI 64063-2372  
(816) 969-1300  
FAX (816) 969-1313  
TDD (816) 969-7407

## PLANS REVIEW CONDITIONS

Permit No:	PRCOM20100267	Date:	December 30, 2010
Project Title:	The Kids Place	Applicant:	
Location:	930 NW BLUE PKWY, Unit:E LEES SUMMIT, MO 64086	AEGIS FIRE PROTECTION	
Type of Work:		11936 W. 119th Street	
Occupancy Group:	M	(913) 825-0343	
Description:	Tenant finish for women's and kids clothing		
Construction Type:	Type IIB (Unprotected)		
Map Page:	195A		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

### **Sprinkler Plan Review**

**Reviewed By: Jim Eden**

**Released for Construction**

1. Fire Department- 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Plans submitted 12/30/2010

2. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Action required: Call (816) 969-1300 to schedule sprinkler and alarm tests.

3. 2006 IFC 510.1- Identification. Fire protection equipment shall be identified in an approved manner. Rooms containing controls for air-conditioning systems, sprinkler risers and valves, or other fire detection, suppression or control elements shall be identified for the use of the fire department. Approved signs required to identify fire protection equipment and equipment location, shall be constructed of durable materials, permanently installed and readily visible.

Action required: Sectional valves and controls shall be clearly marked to indicate the area they serve and accessible. Verified at inspection.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**