

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20210354

Address: 2101 SW M 150 HWY, LEES SUMMIT, MO 640823902 SW PRYOR RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Surface	Eric Sharp	Partial	Thursday, May 12, 2022

Informational:

1	Misc	On 12.15.2021 the contractor, ESS applied 551.29 tons of KS SR 12.5A Comm 64-22 asphalt to the pavement
---	------	---

Corrective Action Required:

2	Misc	The roadway is sinking around MH 3-3, leaving a dip and puddling in the road. Pictures attached. 3/23/22 ES
---	------	---

Informational:

3	Misc	On 4.18.2022 I observed ESS had saw-cut some areas where road failures had occurred.
---	------	--

Informational:

4	Misc	On Thursday, 5-12-2022. ESS & Sons completed asphalt milling of repair areas throughout the project for pavement asphalt repair.
---	------	--

Comments: