

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20212196  
Address: 1630 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Sediment Control (ESC) Inspection</b>	Adam Nacke	Failed	Thursday, May 12, 2022

Corrective Action Required:

1	Miscellaneous Correction	5-12-22 AN silt fence is down around 3 or 4 lots by 4129 NE Georgian Dr. Please take care of this asap because they called in and complained. Also you need to check all the field inlets for silt build up and fix the silt fence that is down in various spots on the 7th and 8th plat.
---	--------------------------	---

**Comments:**