

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20212831
Address: 900 NE DEERBROOK ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Thursday, May 12, 2022

Corrective Action Required:

1	Misc	-Receptacles located within six ft of laundry room sinks must be gfci-protected -Tamper resistant receptacles are required in childcare facility, including receptacle in bathroom and at sink
---	------	---

Comments: