

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212066
Address: 4416 SW TANZANITE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, May 12, 2022

Corrective Action Required:

1	Misc	-maintain erosion control on lot until sod is placed -final driveway inspection required, contact development services to schedule -final grade and sod -splash blocks all downspout and sump pump locations, min 36" discharge from foundation -guardrail required at front porch, more than 30" from grade -provide spark ring at great room floor receptacle, no box setback allowed with combustible surface
---	------	---

Comments: