

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215539  
Address: 122 NW JOSHUA DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Failed	Thursday, May 12, 2022

Corrective Action Required:

1	Miscellaneous Correction	-Fasten top plate to header with 2 rows 16d sinkers at 3" OC per plan-PFH -Strap top plate break at LVLs at SGD-USE 24" strap -Nail intersecting wall corners per code-Garage at single bay -Fire block dead spaces dining room-Need to block all sides to prevent vertical to horizontal fire spread
---	--------------------------	--

Comments: