

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215552
Address: 110 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Thursday, May 12, 2022

Corrective Action Required:

1	Miscellaneous Correction	-Seal fire blocking & upward penetration fireplace-NOT DONE -Strap top plate breaks within 24" garage near front door -USE 24" STRAPS -Engineer to address field modifications to truss M6 foyer-NO CORRECTIONS PERFORMED ON DAMAGES-ALSO ADDRESS END CUT OFF AT FOYER -Fire block dead space above refrigerator-SEAL GAPS AND PENETRATIONS INTO ATTIC SPACE -Seal upward penetrations outside bed 1 door-NOT DONE -Solid fire-block chases filled with insulation-NOT DONE -Strap top plate & provide boca plate at dryer vent-PLATE TO PROTECT 2" BELOW TOP PLATE AND STRUCTURAL STRAP TO EXTEND MIN 6" EACH WAY OF BORE
---	--------------------------	--

Comments: