## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20215472

Address: 2034 SW FARM FIELD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Mitchell Schwarz Failed Thursday, May 12, 2022

Residential

Corrective Action Required:

1 Misc

-3 studs under IvI per plans basement stairwell entry address plans call for stl

beam

\*okay to insulate \*

**Comments:**