

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215616
Address: 2103 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Robb Popp	Not Ready	Thursday, May 12, 2022

Corrective Action Required:

1	Miscellaneous Correction	PROVIDE MIN 10 PSI FOR 15 MIN HAS 0 PSI-5/12/22 Still no pressure
---	--------------------------	---

Comments: