

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215616
Address: 2103 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Thursday, May 12, 2022

Corrective Action Required:

1	Miscellaneous Correction	-POST ADDRESS BEFORE ANY FURTHER INSPECTIONS -No deck pier inspection on record -Engineer to address field modifications to trusses at foyer/ garage -Provide (4) stud pack at girder truss bearing point bed 1-REPAIR OVERNOTCHED STUD AND NAIL PER CODE -Provide stud shoe washing machine drain-USE MANUFACTURER REQUIRED FASTENERS -Truss screws shall extend through double top plate laundry girder-ADDRESS SCREW COMING OUT OF THE SIDE OF THE -Nail exterior wall sheathing above 2 car overhead door-SEE VERTICAL SEAMS -Tighten anchor bolt basement near line set-NOT DONE -Provide (3) 2x6 under beam bed 3/patio door-NOT DONE
---	--------------------------	---

Comments: