

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213590

Address: 3713 SW WALSH DR, LEES SUMMIT, MO 640823715 SW WALSH DR, LEES SUMMIT, MO 640823717  
SW WALSH DR, LEES SUMMIT, MO 640823711 SW WALSH DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Patrick Schonfeldt	Failed	Thursday, May 12, 2022

Corrective Action Required:

1 Misc

UNIT 3711:

- provide vertical fireblock every 10' between studs and fire rock
- provide fire rated plywood at roof deck first 4' from rated wall

UNIT 3713:

- address fire rock not seated in H stud 2nd floor

**Comments:**