

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213590

Address: 3713 SW WALSH DR, LEES SUMMIT, MO 640823715 SW WALSH DR, LEES SUMMIT, MO 640823717  
SW WALSH DR, LEES SUMMIT, MO 640823711 SW WALSH DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:            | Inspector:         | Outcome: | Date:                  |
|------------------------|--------------------|----------|------------------------|
| <b>Erosion Control</b> | Patrick Schonfeldt | Failed   | Thursday, May 12, 2022 |

Corrective Action Required:

|   |                                         |                                               |
|---|-----------------------------------------|-----------------------------------------------|
| 1 | DCM1 ESC<br>REQUIRED NO<br>FURTHER INSP | -GRAVEL FILTER REQUIRED ON DRIVE, MIN 6" LIFT |
|---|-----------------------------------------|-----------------------------------------------|

**Comments:**