

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20212836
Address: 3217 SW ARBORIDGE DR, LEES SUMMIT, MO 64082
Inspected On: Thursday, May 12, 2022
Inspected By: Mitchell Schwarz
Expiration Date: 6/13/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|------------------|---------------------------|
| Occupancy Inspection - Codes Residential | Mitchell Schwarz | Temporary C of O | Thursday, May 12, 2022 |

Corrective Action Required:

1 Misc TCO Until 5/13/22

- sod
- splash block and sump pump discharge to extend 36" from foundation
- check water meter and meter well height at time of sod
- check siding from grade at back of lot