

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20212434
Address: 1837 SW SAGE CANYON RD, LEES SUMMIT, MO 64082
Inspected On: Friday, May 13, 2022
Inspected By: Patrick Schonfeldt
Expiration Date: 6/13/2022 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Temporary C of O	Friday, May 13, 2022

Corrective Action Required:

1	Misc	-Submit as graded plot plan for review and approval, (NO AS GRADED PLOT PLAN HAS BEEN RECEIVED) - water meter required 14" min -18" max clearance from top of meter to top of lid, (CURRENTLY HAS 2 RISES ON WELL, 30" FROM METER TO LID)
---	------	--

****OK FOR TCO - TCO EXPIRES 6/13/22****