

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214073
Address: 432 NW KAYLEA CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Partial	Friday, May 13, 2022

Corrective Action Required:

1	Misc	-fire rating required of exterior walls required per R302.1(1) - exterior layer pyro guard sheathing observed at all rough (Require screw inspection rated assembly)
---	------	--

Comments: