

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215679
Address: 2036 SW WHEATFIELD CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Robb Popp	Failed	Friday, May 13, 2022

Corrective Action Required:

1	Misc	-Identify ufer conductor at both ends -Unable to vefiry ufer connection-possibly covered in garage?. This must be accessible
---	------	---------------------------------------------------------------------------------------------------------------------------------

Comments: