

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204938
Address: 341 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Failed	Friday, May 13, 2022

Corrective Action Required:

1	Miscellaneous Correction	OBTAIN LAWN IRRIGATION PERMIT SUBMIT BACK FLOW CERTIFICATION . ok for tco if needed
---	--------------------------	--

Comments: