

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215869  
Address: 2103 SW HOOK FARM DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Friday, May 13, 2022

Corrective Action Required:

- |   |                          |   |
|---|--------------------------|---|
| 1 | Miscellaneous Correction | <ul style="list-style-type: none"><li>- Straps inside for PFH should include top plate</li><li>- Fire block mud room joist space to great room</li><li>- Fire block penetration at top plate kitchen</li><li>- Provide flashing at dining room windows</li><li>- Provide windows master bathroom</li><li>- Fire block soffit vertical to horizontal left and right side of bar basement</li><li>- Add support to basement soffit over 4' in width</li></ul> |
|---|--------------------------|---|

Comments: