

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20204934  
Address: 1440 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Michael Harkins	Partial	Friday, May 13, 2022

Corrective Action Required:

1	Miscellaneous Correction	EXTERIOR WALL SHEATHING OK TO COVER
		ROOF SHEATHING NAILING APPROVED OK TO COVER
		PROVIDE CITY APPROVED TRUSS PLANS & LAYOUT
		PROVIDE ANCHOR BOLTS WITHIN 12" OF PLATE BREAKS NORTH WALL
		NO WINDOW FLASHING ON WOOD SILLS

**Comments:**