

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221788
Address: 4709 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Adam Nacke	Passed	Friday, May 13, 2022

Informational:

1	Miscellaneous Correction	5-10-22 Holthouse josh— fire hydrant was moved to make way for the driveway but they did not move the valve. Valve needs to be moved 20in - 42in from the hydrant. Also no one was made aware that the hydrant was being moved. Make sure the valve is not in the driveway
---	-----------------------------	--

Informational:

2	Misc	5-13-22 AN crew has began to move hydrant valve
---	------	---

Informational:

3	Misc	5-13-22 AN water hydrant and valve have Been moved. Also the hydrant was flushed
---	------	--

Comments: