

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20221788
Address: 4709 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Adam Nacke	Failed - Stop Work	Tuesday, May 10, 2022

Informational

1	Miscellaneous Correction	5-10-22 Holthouse josh— fire hydrant was moved to make way for the driveway but they did not move the valve. Valve needs to be moved 20in - 42in from the hydrant. Also no one was made aware that the hydrant was being moved. Make sure the valve is not in the driveway
---	--------------------------	--

Informational

2	Misc	5-13-22 AN crew has began to move hydrant valve
---	------	---

Comments: