

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215828
Address: 2047 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Friday, May 13, 2022

Corrective Action Required:

1	Misc	REQUESTED INSPECTION(S) DENIED DUE TO DEFICIENT EROSION CONTROL INSTALLATION. -ESTABLISH GRAVEL FILTER MIN. 6" LIFT OF MIN. 3/4" GRAVEL TO HOUSE, PROVIDE EROSION CONTROL METHODS AT PERIMETER OF LOT
---	------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: