

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215185  
Address: 2035 SW WHEATFIELD CT, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Monday, May 16, 2022

Corrective Action Required:

1	Misc	-uncover PFG at garage to inspect nailing to header -missing anchor bolt at PFG -fire block above fire place seal all gaps and penetrations -fire block master closet window furr down -address from door wall framing plans call for 3 king 1 trimmer -fire block bed 2 closet into furr down -fire block furr out in bed 2 bath -have engineer address the framing of his area
---	------	---

Comments: