

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212957
Address: 1532 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------------|----------|----------------------|
| All Rough Inspection - Residential | Patrick Schonfeldt | Failed | Monday, May 16, 2022 |

Corrective Action Required:

| | | |
|---|--------------------------|---|
| 1 | Miscellaneous Correction | -LIB bracing all locations per plans, (have engineer clarify location LIB bracing at closet master bed hall) -land all electrical to boxes and secure NM at areas removed for girder truss stud pack kitchen and 2nd floor stairs OK FOR INSULATION |
|---|--------------------------|---|

Comments: