

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211697  
Address: 4737 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                     | Inspector:   | Outcome: | Date:                |
|---|--------------|----------|----------------------|
| <b>Occupancy Inspection - Codes Residential</b> | Khanh Nguyen | Failed   | Monday, May 16, 2022 |

Corrective Action Required:

|   |      |  |
|---|------|--|
| 1 | Misc | -Driveway not approved on record<br>-Final grade, sod, downspout and sump pump extension<br>-Upper stair handrail not extended to top stair riser<br>-Provide combustible air openings for upper floor furnace |
|---|------|--|

Comments: