CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #:PRRES20215294Address:2104 SW HARVEST MOON LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspectior	1:	Inspector:	Outcome:	Date:
Gas Servio Residentia	ce Inspection - al	Mitchell Schwarz	Failed	Monday, May 16, 2022
Corrective Action Required: 1 Misc		inspection denied insulator	in home blowing insulation	
		-provide pressure gauge with minimum 10psi for inspection		

Comments: