

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212524
Address: 1816 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Monday, May 16, 2022

Corrective Action Required:

1	Miscellaneous Correction	<ul style="list-style-type: none">- final grading and sod- Splash blocks- Driveway inspection pending- Sidewalk inspection pending- Outlets at island not GFCI protected- Provide steps for Egress window- Provide spark rings at bar counter outlets- Missing switch plate near bar
---	-----------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: