



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20100205, Building Permit - Commercial  
Address: 350 SW BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	John Borns	Partial	Tuesday, January 04, 2011

### Partial Correction

1 MISC

OK TO COVER WHEN READY: SOFFITS; WALL FRAMING AND IN-WALL SYSTEMS EXCEPT PLUMBING WALLS

### Corrective Action Required

2 MISC

IN-WALL PLUMBING: INSTALL CODE-CONFORMING SHIELD PLATES TO PROTECT PVC AND COPPER PIPING WHERE LESS THAN 1-1/2" FROM FACE OF FRAMING; INSTALL GROMMETS TO PROTECT COPPER PIPING WHERE PASSING THROUGH STEEL STUDS

### Comments: