Keystone LABORATORIES, INC.

ANALYTICAL REPORT

May 11, 2022

Work Order: 1FE0967

Report To	Work Order Information
Eric Sharp	Date Received: 05/10/2022 9:00AM
City of Lee's Summit - Public Works Dept.	Collector: Sharp, Eric
220 SE Green Str	Phone: (816) 969-7428
Lees Summit, MO 64063	PO Number: Routine Analysis

Project : Holthouse Construction

Project Number: Chapel Ridge Townhomes

Analyte	Result	MRL	Batch	Method	Analyst	Analyzed	Qualifier
1FE0967-01 Fire Line 1				Matrix:Drink Wtr		Collected: 05/09/22 11:15	
Total Coliforms	<1.0 MPN/100ml	1.0	1FE0497	9223B-QT	CLJ	05/10/22 14:15	
E. Coli	<1.0 MPN/100ml	1.0	1FE0497	9223B-QT	CLJ	05/10/22 14:15	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.

City of Lee's Summit - Public Works Dept.
220 SE Green Str
Lees Summit, MO 64063

Work Order: 1FE0967

May 11, 2022
Page 2 of 3

Certified Analyses included in this Report

Method/Matrix	Analyte	Certifications
9223B-QT in Drink Wtr		
	Total Coliforms	KS-KC,MO-KC
	E. Coli	KS-KC,MO-KC

Code	Description	Number	Expires
KS-KC	Kansas Department of Health and Environment-KC	E-10110	04/30/2022
KS-NT	Kansas Department of Health and Environment (NELAP)	E-10287	10/31/2022
MO-KC	Missouri Department of Natural Resources	140	04/30/2022
SIA1X	Iowa Dept. of Natural Resources (updated certificate pendin	95	02/01/2024

End of Report

Keystone Laboratories, Inc.

Carolyn Jackson
Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.

CHAIN OF CUSTODY RECORD

Keystone LABORATORIES, INC.

600 E. 17th St. S
Newton, IA. 50208
Phone:641-792-8451

___ 3012 Ansborough Ave
Waterloo, IA. 50701
Phone:319-235-4440

X 835 S St. Paul
Kansas City, KS. 66105
Phone:913-321-7856

___ 205 E Van Buren St
Centerville, IA. 52544
Phone: 641-437-7023

PRINT OR TYPE INFO BELOW:	REPORT TO:	BILL TO:
SAMPLER: Eric Sharp	NAME: Eric Sharp	NAME: Travis Holthouse
SITE NAME: Chapel Ridge Townhomes	CO. NAME: City of Lee's Summit	CO. NAME: Holthouse Construction
ADDRESS: 3635 NE Akin Dr	ADDRESS: 220 SE Green St	ADDRESS: P.O. Box 1197
CITY/ST/ZIP: Lee's Summit, MO 64086	CITY/ST/ZIP: Lee's Summit, MO 64063	CITY/ST/ZIP: Liberty, MO 64069
PHONE: 816-969-1206	PHONE: 816-969-1206	PHONE: 816-781-6796
	Email: Eric.Sharp@cityofls.net	Email: Travis@Holthouseconstruction.com

CLIENT SAMPLE #	DATE	TIME		# OF CONTAINERS	MATRIX	GRAB/COMPOSITE	ANALYSES REQUIRED: Total Coliform							Sample Condition	Sample #
Fire Line 1	5/9/22	11:15		1	DW	G	X								IFE0967-01

LAB USE ONLY

Wk Order #:		IFE0967
Short Hold:		
Rush:		
Temp.	oC	Ambient

Relinquished by: (Signature)	Date: 5/9/22 Time: 12:00	Received by: (Signature)	Date: 5/9/22 Time: 1200	Remarks:
Relinquished by: (Signature)	Date: Time:	Received for Lab by: (Signature)	Date: 05/10/22 Time: 09:00	