

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20204934
Address: 1440 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Partial	Friday, May 13, 2022

Corrective Action Required:

1	Miscellaneous Correction	EXTERIOR WALL SHEATHING OK TO COVER
		ROOF SHEATHING NAILING APPROVED OK TO COVER
		PROVIDE CITY APPROVED TRUSS PLANS & LAYOUT
		NO WINDOW FLASHING ON WOOD SILLS

Comments: